

**TRADE WASTE AND EFFLUENTS RESEARCH UNIT (REGIONAL LAB)
PATIALA**

Room No. 301, 2nd Floor, Water Supply & Sanitation Department, Head Office, Nabha Road, Patiala
researchunitpatiala@yahoo.in

To,

AGGARSAIN INTERNATIONAL PUBLIC SCHOOL,
Near Punjab National Bank, Main Road, Samana.

No.: TWERU/2526/00576 Dated : 10/10/2025

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 9394 Dated: 08/10/2025

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 08/10/2025. It is request to fill the attached feedback form and send it back to Trade Waste and Effluents Research Unit (Regional Lab) Patiala

D/A : Test Report



**Authorized Signatory
For, Trade Waste and Effluents Research Unit
(Regional Lab) Patiala**

TRADE WASTE AND EFFLUENTS RESEARCH UNIT (REGIONAL LAB)

PATIALA

Room No. 301, 2nd Floor, Water Supply & Sanitation Department, Head Office, Nabha Road, Patiala
researchunitpatiala@yahoo.in

TEST REPORT

Name & Address of Customer : AGGARSAIN INTERNATIONAL PUBLIC SCHOOL, Near Punjab National Bank, Main Road, Samana.		Customer Reference No.	No : 9394 Dated : 08/10/2025
		Sample Submitted by	
		Date of Sample Receipt	08/10/2025
		Analysis Starting Date	08/10/2025
		Analysis completion Date	10/10/2025
Discipline : Bacteriological Testing		Group: Water	
ULR No.:		Sample Type :	Water
Test Report No.:	TWERU/2526/00576	Date of Issue :	10/10/2025
Registration no.:	TWERU/REG2526/03729	Condition of Sample :	Unsealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	2000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Ro at AGGARSAIN INTERNATIONAL PUBLIC SCHOOL, Samana, Patiala. / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Not Mentioned	District :	Patiala
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	Total Coliform(TC)	ND	Shall not be detectable in any 100 ml sample	No relaxation	MPN/100 ml.	IS-1622 MPN Method
2	E-Coli	ND	Shall not be detectable in any 100 ml sample	No relaxation	MPN/100 ml.	IS-1622 MPN Method
3	Residual Chlorine(RC)	ND	0.2	1	mg/l	IS-3025 (Part-26) by Iodometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Sh. Brij Bhushan
Quality Manager
Authorized Signatory
For, Trade Waste and Effluents Research Unit
(Regional Lab) Patiala

End of the Test Report